



Member of the FM Global Group

FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

CERTIFICATE OF COMPLIANCE

HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS

This certificate is issued for the following equipment:

5a37-bcdefg-hi-jklm. Digital Positioner.

IS/II/1/ABCD/T4 Ta = -20°C to 85°C, T6 Ta = -52°C to 45°C; - 291780; Entity

I/O/Ex ia IIC/T4 Ta = -20°C to 85°C, T6 Ta = -52°C to 45°C; - 291780; Entity

NI/II/2/ABCD/ T4 Ta = -20°C to 85°C, T6 Ta = -52°C to 45°C

Type 4X, IP66

Entity Parameters:

	4-20 Input	MFC Card	Limit Switch -02
Ui (V)	30	30	10.6
Ii (mA)	100	100	29.7
Pi (mW)	800	800	79
Ci (nF)	0	0	1
Li (µF)	47	0	1

Remote Mount Terminals	
Uo (V)	5
Io (mA)	79
Po (mW)	129
Co (µF)	2
Lo (µH)	100

a = Communication and Diagnostics: 05+, 10+, 20MD+, 21MD+ or 22MD+.

b = Housing: W, Y, B or A.

c = Threaded Connection: 1, 2 or 3.

d = Shaft: D or R.

e = Action: 1, 2 or 3.

f = Position Indicator: 0, F or D.

g = Special Options: 0 or 1.

h = Manifold: 00 or GM.

i = Pressure Gauge: 0, 1, 2, 3, 4, A or B.

j = LCD: 0 or 1.

k = Auxiliary Card slot 1: 0 or 2 1.

l = Auxiliary Card slot 2: 0 or 1.

m = Limit Switch or Remote Mount: 2 or 7.

Special Conditions of Use:

1. To prevent the risk of electrostatic sparking the enclosure shall only be cleaned with a damp cloth.

To verify the availability of the Approved product, please refer to www.approvalguide.com

2. The Digital Positioner enclosure contains aluminum and is considered to present a potential risk of ignition by impact or friction. Care must be taken into account during installation and use to prevent impact or friction.

420-40-abc-de. Digital Positioner.

IS/II/1/ABCD/T4 Ta = -20°C to 85°C, T6 Ta = -52°C to 45°C - 314746; Entity

I/O/Ex ia IIC/T4 Ta = -20°C to 85°C, T6 Ta = -52°C to 45°C - 314746; Entity

Type 4X, IP66

Entity Parameters:

	4-20 Input
Ui (V)	30
Ii (mA)	100
Pi (mW)	800
Ci (nF)	0
Li (µH)	47

a = General Option: W or N.

b = Threaded Connection: 1, 2 or 3.

c = Feedback Shaft: D or R.

d = Gauge: 0, 1, 2, 3, 4, A or B.

e = Display: 0, 1 or 2.

Special Conditions of Use:

1. To prevent the risk of electrostatic sparking the enclosure shall only be cleaned with a damp cloth.
2. The Digital Positioner enclosure contains aluminum and is considered to present a potential risk of ignition by impact or friction. Care must be taken into account during installation and use to prevent impact or friction.

Equipment Ratings:

Intrinsically Safe for Class I, Division 1, Groups A, B, C and D indoor and outdoor (Type 4X and IP66) hazardous locations in accordance with drawing 291780 and 314746, Intrinsically Safe for Class I, Zone 0, Group IIC indoor and outdoor (Type 4X and IP66) hazardous locations in accordance with Control Drawing 291780 and 314746, Nonincendive for Class I, Division 2, Groups A, B, C and D indoor and outdoor (Type 4X and IP66) hazardous Locations.

FM Approved for:

Flowsolve US Inc
Springville, UT United States

To verify the availability of the Approved product, please refer to www.approvalguide.com



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

CAN/CSA C22.2 No. 157	2012
CAN/CSA C22.2 No. 213	2008
CAN/CSA C22.2 No. 1010.1	2009
CAN/CSA No. 60079-0	2011
CAN/CSA No. 60079-11	2011
CAN/CSA C22.2 No. 60529	2005

Original Project ID: 3044377c

Approval Granted: September 7, 2012

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
3047577	November 21, 2012		
130104	January 11, 2013		
3049443	January 20, 2014		
140124	March 12, 2014		

FM Approvals LLC



J. E. Marquedant
Group Manager, Electrical



Date

To verify the availability of the Approved product, please refer to www.approvalguide.com